



TRIPURA RENEWABLE ENERGY DEVELOPMENT AGENCY
(A Constituent Organization of Power Deptt., Government of Tripura)
Vigyan Bhawan, Pandit Nehru Complex, Gorkhabasti, Agartala, Tripura
Tele-fax: 0381-2325900, 2326139, email-tredaagartala@gmail.com

No.F. 6(259)/TREDA/NCES/19/3680

Date 03/03/2020

AMENDMENT 2

NAME OF WORK:	Design, manufacture, supply, erection, testing and commissioning of Solar PV Power Plants on turn-key basis including Warranty / Guarantee and Annual Maintenance Contract for 5 (five) years from the date of commissioning in various Government installations in the State of Tripura
DNIe-T	No.F. 6(259)/TREDA/NCES/19/3157, dated 11/02/2020
CORRIGENDUM 1	No.F. 6(259)/TREDA/NCES/19/3484, dated 20/02/2020
AMENDMENT 1	No.F. 6(259)/TREDA/NCES/19/3513, dated 25/02/2020
TENDER ID	2020_TREDA_8431_1

In addition to the amendments made in Amendment 1, the following amendments have been made in above e-tender:

REFERENCE OF CLAUSE IN DNIe-T		APPEARED AS	AMENDED AS
PART - 4: SCOPE OF WORK & TECHNICAL SPECIFICATIONS	CLAUSE NO. 2.3: TECHNICAL SPECIFICATIONS OF 10 KW_p SPV POWER PLANT	SUB-CLAUSE NO. 8: BATTERY BANK	8.1: Type: Tubular GEL Type
	CLAUSE NO. 2.4: TECHNICAL SPECIFICATIONS OF 5 KW_p SPV POWER PLANT	SUB-CLAUSE NO. 8: BATTERY BANK:	8.1: Type: Tubular GEL Type
	CLAUSE NO. 2.5: TECHNICAL SPECIFICATIONS OF 5 KW_p SPV POWER PLANT	SUB-CLAUSE NO. 8: BATTERY BANK:	8.1: Type: Tubular GEL Type

3/3/2020

PART 6: TECHNICAL BID	Clause No. 6.3	--	6.3: Tubular GEL Battery	6.3: Tubular GEL / / AGM VRLA Battery
		ADDITIONAL SUB-CLAUSE		6.3.10: Type of battery:
	Clause No. 6.4	--	6.4: Tubular GEL Battery	6.4: Tubular GEL Type / AGM VRLA Type
		ADDITIONAL SUB-CLAUSE	--	6.4.9: Type of battery:
PART - 7: QUALITY CERTIFICATION, STANDARDS AND TESTING FOR SOLAR PV POWER PLANTS	Clause No.7.1.3:	ADDITIONAL SUB-CLAUSE	--	IS:15549:2005: Stationary Valve Regulated Lead Acid Batteries – specifications
				IEC 60896 – 21 & 22: 2004-02: Stationary lead-acid batteries – Valve regulated types – Methods of test

“**Tubular GEL Type**” appeared in any Clause of the DNIE-T may be read as “**Tubular GEL Type / AGM VRLA Type**”.

Other terms & conditions of the DNIE-T and Corrigendum 1 and Amendment 1 (Except PART 6: TECHNICAL BID) will remain unchanged.

1. The last date of e-bidding is hereby extended upto **16/03/2020 upto 03:30 PM.**
2. Technical bid opening date: **16/03/2020 at 04:00 PM.**

D S DAS
3/3/2020

(D S DAS)
Joint Director

D S DAS
3/3/2020