



TRIPURA RENEWABLE ENERGY DEVELOPMENT AGENCY  
A Constituent Organization of Power Department, Government of Tripura,  
Vigyan Bhawan, Pandit Nehru Complex, Gorkhabasti, Agartala, Tripura,  
Ph-0381-2325900(Fax), 2326139,email- tredaagartala@gmail.com

No.F.6(247)/TREDA/NCES/2019/821

Date 04/07/2019

**CORRIGENDUM-2**

- REF: i) DNE-T No.F.6(247)/TREDA/NCES/2019/485, dated 30/05/2019,  
ii) Memo. No.F.6(247)/TREDA/NCES/2019/723, dated 24/06/2019,  
iii) Corrigendum I vide Memo No.F.6(247)/TREDA/NCES/2019/743, dated 27/06/2019.

In addition to the amendments made in Memorandum No.F.6(247)/TREDA/NCES/2019/723, dated 24/06/2019, Corrigendum I vide Memo No.F.6(247)/TREDA/NCES/2019/743, dated 27/06/2019 the following amendments have been made in above e-tender for supply of ISI marked I phase & 3 phase Net Meter with meter box for net metering (Solar Application) including 5 (five) years guarantee / warranty and maintenance:

Reference Clauses	Appeared as per DNE-T	Amend as
<b>Annexure-1(A) Sl. No.1: Scope</b>	This specification is for supply of Single Phase Net Meter for direct measurement of single phase alternating current energy at standard frequency of 50 Hz and associated communication hardware & software. <b>The meter shall be capable to measure kWh and kWh independently</b>	This specification is for supply of Single Phase Net Meter for direct measurement of single phase alternating current energy at standard frequency of 50 Hz and associated communication hardware & software. <b>The meter shall be capable to measure kWh import, kWh export and defrauded energy independently.</b>
<b>Annexure-1(A) Sl. No.7: Anti-Tamper Features</b>	➤ Over current tamper is detected when the consumer draws load more than the configurable meter specific set value of current/power. Persistence time for occurrence & restoration - 10 mins.	<b>Deleted.</b>

1. The reference voltage for 1 phase and 3 phase Net Meters shall be read as 240 Volt.
  2. Standard frequency range shall be as per IS 13779 ( $\pm 5\%$ )
  3. The technical specifications given at Annexure 1(A) & 1(B) is indicative with reference to IS standards. However, the latest amendments in respect of such specifications shall be applicable where necessary. The intending bidders shall mention such modifications in their proposal with reference to relevant clauses of latest IS standard as amended up to the date of publication of e-tender.
- All other terms & conditions of the DNE-T No.F.6(247)/TREDA/NCES/2019/485, dated 30/05/2019 shall remain unchanged.

  
(D.S.DAS)  
Joint Director